



Tim Mulliner
Technical Director - Environment
Alexis Guidon
Water Engineer

Managing a small volume of seepage (Reefton Restoration Project)

➤ **Diversion, Dilution, Treatment, or a little bit of everything?
Saddle Dam Seepage – from Optioneering to Construction**



New Zealand

AusIMM New Zealand Branch Annual Conference - Enabling a Sustainable Future

20 - 22 August 2023
Rydges Latimer Christchurch

Overview

- ➔ Aim of Project
- ➔ Options Analysis
- ➔ Multi Criteria Analysis (MCA)
- ➔ Concept – Detailed Design
- ➔ Construction



→ Aim of Project

Globe Progress / Saddle Dam

Operational 2006 – 2016

Reefton Restoration Project 2016 - Current





Aim of project

↳ Long-term solution for management of seepage water from Saddle Dam Embankment

Table 1 Saddle PTS design dissolved contaminant concentration and load (Verum Group, November 2021)

Parameter	Quantity		Source
	Concentration	Load	
Flow Rate	118 m ³ /day (1.37 L/s)		GHD (2020)
	(g/m ³)	(g/d)	
As	3.0	352	≈85 th percentile of 2020/2021 dataset
Sb	0.005	0.61	Median 2020/21 dataset (Conc.)
Fe	12.2	1,444	Median 2020/21 dataset (Conc.)
Sulphate	148	17,413	Median 2020/21 dataset (Conc.)
pH	7.6	-	Median 2020/21 dataset (Conc.)
Alkalinity	319	37,684	Median 2020/21 dataset (Conc.)
Fe:As Ratio	4.1:1		

Potential visual / amenity risk

→ Option analysis, MCA and solution selection

Options analysis

Target :

Reduction in iron concentration to reduce risk of iron precipitation in receiving environment

Main challenges:

- **Site Access**
- **Low Maintenance / Operator input solution**
- **Limited footprint**
- **No access to reticulated power supply**



Options Analysis / Fatal Flaw


Oxidising / Reducing / Water Management Solutions

Table 4 Treatment Technology/Method Options – Fatal Flaws Assessment


#	Source	Technology Category	Technology	Cost Fatal Flaw?	Footprint Fatal Flaw? (>200-300m ²)	Complexity (Process, O&M) Fatal Flaw?	Novel System Fatal Flaw	Treatability Fatal Flaw?	Fatal Flaws	Area/Size (m ²)	Pros	Cons
1	Verum Spreadsheet	Oxidising System	Cascade	No	No	No	No	Yes	Yes (Poor Treatment i.e. Staining)	20	<ul style="list-style-type: none"> Inexpensive Proven 	<ul style="list-style-type: none"> Fe will precipitate downstream Minimal treatment
2	Verum Report	Oxidising System	Horizontal Flow Pond	Not Rated	Potential	No	No	Potential	Potential (Excessive Footprint & low Treatment)	354	<ul style="list-style-type: none"> No piping Proven 	<ul style="list-style-type: none"> Low Fe, As removal Periodic sludge removal Fe ppt density low
3	Verum	Oxidising System	Aerobic Wetland	Not Rated	Yes	No	No	No	Yes (Excessive Footprint)	787	<ul style="list-style-type: none"> No piping Proven Aesthetic qualities Potential for As uptake by plants 	<ul style="list-style-type: none"> Periodic and difficult sludge removal Fe precipitate density low. Replanting every 2 years (Verum) or up to 5 years (GHD) Possible plant disposal issues.
4	Verum	Oxidising System	Cascade + VFR	No	No	No	No	No	None	265	<ul style="list-style-type: none"> Proven Fe ppt density high 	<ul style="list-style-type: none"> Periodic sludge removal at a difficult to reach site Some staining may still occur Expensive piping network and construction costs.
5	Verum Report	Oxidising System	Supplemental Iron Addition + VFR	Yes	No	Yes	No	No	Yes (High OPEX & requires frequent O&M at difficult site)	265	<ul style="list-style-type: none"> High As removal Proven Possibly could use Devil's ppt 	<ul style="list-style-type: none"> More Fe to remove, may decrease Fe removal Expensive May increase sludge accumulation rates
6	Verum Report	Oxidising System	Steel Slag Leaching Bed	No	Unknown	Yes	Yes	Potential (As removal not used at full scale)	Yes (Too novel and complex)	N/A	<ul style="list-style-type: none"> Small area required Effective for Fe removal 	<ul style="list-style-type: none"> Experimental for As removal (Verum) Fe ppt can plug system Slag from Ni
7	Verum / GHD	Water Management	Pump back up to Fossickers (or discharge to existing VFR)	No	No	No	No	No	None	30	<ul style="list-style-type: none"> Low maintenance No discharge off site 	<ul style="list-style-type: none"> Minor additional Fe accumulation at large VFR.
8	GHD	Water Management	Gravity to existing VFR (HDD through hill)	No	No	No	No	No	None	30	<ul style="list-style-type: none"> Very low maintenance No discharge off site 	<ul style="list-style-type: none"> Expensive (CAPEX)
9	Verum	Reducing System	Bioreactor	Yes	Yes	Yes	No	No	Yes (Significant O&M)	590	<ul style="list-style-type: none"> Proven Good As and Fe removal 	<ul style="list-style-type: none"> Poor removal in cold




Options to Multi Criteria Analysis




Option 1. Cascade + VFR



Option 2. Pump to Fossickers / Devils Creek VFR



Option 3. Gravity to Devils Creek VFR



Option 4a. Dilution with Small Pond (Siphon)



Option 4b. Dilution with Small Pond (Gravity)

Multi-Criteria Analysis



- 4 options assessed
- CAPEX / OPEX / reliability / O&M inputs / performance
- Sensitivity Analysis on weighting parameters


Table 8 Sensitivity Analysis

	Default Weighting + Default Scoring	Default Weighting + Low Option 4 CAPEX Score	Default Weighting + Low Option 3 OPEX Score	High-Cost Weighting + Default Scoring	High-Cost Weighting + Low Option 4 CAPEX Score
Weightings					
CAPEX	15%	15%	15%	40%	40%
OPEX and Maintenance Costs	25%	25%	25%	20%	20%
Treatability / Technical performance Risk / Certainty of Performance	20%	20%	20%	20%	20%
Operations & Maintenance complexity/frequency, H&S (No costs)	20%	20%	20%	10%	10%
Reliability	20%	20%	20%	10%	10%
Total	100%	100%	100%	100%	100%
Score Sensitivity					
Option 1 - Cascade + VFR	500	500	500	500	500
Option 2 - Pump back up to Fossickers (or discharge to existing VFR)	555	555	555	600	600
Option 3 - Gravity to existing VFR (HDD through hill)	625	625	550 ²	520	520
Option 4 - Dilution with Small Pond for Seepage Only	745	700 ¹	745	730	610 ³

Solution to design

Two infrastructure streams:

- Leachate collection and oxidation / settlement
- Dilution water from basin to mixing zone




→ Design & Construction

Design to construction

Dilution water supply - siphon



- Supply 10 L/s
- Floating Inlet
- Low maintenance / operator input
- Basin water levels
- Geometrical constraints



Design to Construction

Dilution water supply - Priming

- Pressure break tank at siphon outlet
- Water storage for siphon re-priming
- Easy access from top of embankment
- Alarm for siphon break







Design to Construction

Leachate Treatment

- Provide some aeration and settlement to reduce iron
- Maximise retention time
- Minimise footprint and earthworks requirements
- Safety in Design and geotechnical considerations




Design to Construction

Leachate treatment

Concrete pre-cast channels available on-site from previous project


Re-purposing otherwise un-used assets

Lower CAPEX, good volume retention



Iterative process to identify:


- Best volume retention
- Best hydraulic efficiency for sedimentation
- Best volume / footprint compromise




Design to Construction

Leachate Treatment

Retained solution



Source: OceanaGold



Source: OceanaGold

Current progress

- Consent granted
- Construction complete
- System commissioning underway
- Awaiting the first test results





Acknowledgements

→ All parties involved





Managing a small volume of seepage

Questions?



New Zealand

AusIMM New Zealand Branch Annual Conference - Enabling a Sustainable Future

20 - 22 August 2023
Rydges Latimer Christchurch